



# Certificate of Continued Compliance 192350035/AA/01



Issued 12-04-2023  
Expiry date 12-04-2027

Replaces 192350035/AA/00  
Page 1 / 4

In compliance with the procedure specified in the **Alarm Components Scheme**, Kiwa FSS products declares that the stated alarm equipment complies with the technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description: Wireless Magnet Detector  
Trademark: Vanderbilt  
Type designation: WMAG-I  
Hardware / Software: 02 / 1.0.0

Placed on the market under the name or trademark of:

Name of the manufacturer: Vanderbilt International (IRL) Ltd.  
Address: Clonsaugh Business & Technology Park  
City: 17 DUBLIN  
Country: Republic of Ireland

This certificate is granted to:

Name of the certificate holder: Vanderbilt International (IRL) Ltd.  
Address: Clonsaugh Business & Technology Park  
City: 17 DUBLIN  
Country: Republic of Ireland

Ron Scheepers  
Managing director

*This certificate has THREE Annexes.*

Kiwa Nederland B.V.  
Kiwa FSS Products  
Wilmsdorf 50  
Postbus 137  
7300 AC Apeldoorn  
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>



## Remarks and observations

The following conditions are applicable:

Security grade: 2

Environmental class: II

Equipment class: Fixed

Power supply type: C

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 2.

Electromagnetic emission and safety aspects are not covered by this certificate.

Factory location:

Crow Electronic Engineering Ltd

HaMasger St. 2

Afula

Israel

Product inspection location:

SmartSD BV

Broekakkerweg 15

5126 BD Gilze

Netherlands

**Documentation lodged for this Certificate of Continued Compliance****Test Reports:**

- Hermon Laboratories Ltd.: CROIAS\_EN 50131-2-6.32660\_1, 07 April 2019
- Hermon Laboratories Ltd.: CROIAS\_EN 50131-6.32660\_1, 07 April 2019
- Hermon Laboratories Ltd.: CROENV\_EN.30794.2\_Rev1, 25 March 2019
- Hermon Laboratories Ltd.: CROEMC\_EN.30794\_v, 09 May 2018
- Hermon Laboratories Ltd.: CRORAD\_EN.30794\_EN 50131-5-3\_v, 04 November 2018
- ANPI asbl: bis-rec-1430-00\_Class II Wireless Indoor products for SO2 test\_Crow Electronic Engineering Ltd, 25 April 2018

**Product Documentation:**

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

**Technical Standards and Specifications**

The product shows no non-compliances with:

EN 50131-2-6

September, 2008

**Applied Standards**

EN 50130-5

June, 2011

EN 50130-4+A1

October, 2014

EN 50131-5-3

March, 2017

EN 50131-1+A1+A2+A3

June, 2020

**The product as described in this certificate includes the following type designations**

- Product description: Wireless Magnet Detector
- Trademark: Vanderbilt
- Type designation: WMAG-I
- Hardware version: 02
- Software version: 1.0.0