

Intruder alarm control and indicating equipment (CIE) “Omnis system”

Issued to

Vanderbilt International (Irl) Ltd

Clonshaugh Business and Technology Park, Dublin D17 KV84, Ireland

Product name

Omnis, for details see appendix.

Product description

Intruder alarm control and indicating equipment (CIE) in accordance with EN 50131-3:2009.

Certificate

The product described above has been type-examined by RISE and found to fulfil the requirements set out in standard EN 50131-3:2009, Alarm systems, Intrusion and hold up systems, Part 3: Control and indicating equipment, March 2009. The product is tested as an intruder alarm system. For security grade and environmental class see appendix. Basis for this certificate is test report no. P116990.DP01.A01, dated 2023-09-22, issued by RISE Research Institutes of Sweden AB, Electrification and Reliability - Safe Control Systems.

Marking

Each product that conforms in all respects with the original item type-examined may display the text 'Type examined by RISE'. When this marking is applied the marking shall also show the number of the standard, classification/category of the item (if applicable), the number of this certificate and the serial number or equivalent of the item.

Validity

This certificate is valid until not later than 2026-02-01. The validity of this certificate can be verified by RISE.

Miscellaneous

Other terms and conditions are set out in RISE Certification rules for type-examination of Alarm Systems, SPCR 180. This is the 3 issue of this certificate, originally issued on 2021-02-01. This edition of the certificate replaces previous editions.

A blue ink signature of Martin Tillander, consisting of a stylized 'M' followed by a long horizontal stroke.

Martin Tillander

Certificate C900318 | issue 3 | 2023-11-02

RISE Research Institutes of Sweden AB | Certification

Box 857, SE-50115 Borås, Sweden

+46 10 516 50 00 | certifiering@ri.se | www.ri.se

P116990

This document is the property of RISE and may not be reproduced other than in full, except with the prior written approval by RISE

Specification

The type examination covers the following components, which has shown the security grade and environmental class according to the table:

Component	Security grade	Environmental class
Central controller E100	3	II
Central controller E100-S	3	II
Door controller E200	3	II
Repeater unit E500	3	II
Card reader VR10S	3	III
Card reader VR20M	3	III
Keypad and card reader VR40 S	3	III
Keypad and card reader VR50 M	3	III
Keypad M5	3	II
Keypad M6	3	II
PX Power supply(also defined as Omnis PSU): External power supply NOVA 2730 XS2/ NOVA 2750-FLX/ NOVA 27100 -FLX/ NOVA 27150-FLX	3	I