




Member of



# Certificate of Conformity with European standards for Components and Systems

---

Number of Certificate	Valid from dd-mm-yyyy	Valid until dd-mm-yyyy
<b>EN-ST-000196</b>	<b>14-06-2019</b>	<b>11-12-2022</b>

---

*Subject matter of Certificate:*

**Alarm transmission equipment  
SPCN 110**

---

*Owner of Certificate:*

**Vanderbilt International (IRL) Ltd.  
Clonshaugh Business & Technology Park  
IE-D17 KV84 DUBLIN 17**

---

*Basis for certification:*

**EN 50136-2:2013**

---

*Use, the product disposes of the following parameters:*

**Intrusion and hold-up systems, Grade 3**

---

*The tests were carried out at VdS Schadenverhütung GmbH  
and the results are documented in test report:*

**141914-AU01 dated 25-03-2015**

---

**VdS Schadenverhütung GmbH**  
Certification Body  
Amsterdamer Str. 174  
D-50735 Köln

A company of the German  
Insurance Association (GDV)  
accredited by DAkkS as certifica-  
tion body for fire protection and  
security products



*To guarantee the permanent quality of products a regular surveillance of the manufacturing process is performed.*

*This certificate comprises 4 pages and shall only be reproduced without any modifications and including all enclosures.*

Date: 29-05-2019

Managing director

Head of certification body



To Certificate No.: EN-ST-000196

Date : 29-05-2019

The approved component/system comprises the following parts:

Description of component	Type	Applicant's Registration No.	Approval number of component (only complete for system approval)
<p>Communication module for the PSTN transmission path for mounting inside the G2 and G3 enclosures of the SPC I-CIE series.</p> <ul style="list-style-type: none"><li>- Hardware Revision: A1</li><li>- Software Revision: V2.10</li></ul>	SPCN 110.000	V54550-B101-A100	



To Certificate No.: EN-ST-000196

Date : 29-05-2019

The approved component/system is described as follows:

Type of document	Manufacturer's identification	Date	Number of Pages
Installation Manual:			
- SPCN110	A6V10209199	04.03.2013	8
- SPC Installation and Configuration (En)	A6V10276959, Rev. 3.6	28.11.2014	363
- SPC Installation and Configuration (De)	A6V10271081, Rev. 3.6	28.11.2014	396
Drawings:			
- Circuit diagram	E-PC137421	13.11.2008	2
- Bill of Material	V54550-B101-A100	26.09.2011	3
- Assembly diagram	E-PC137421	13.11.2008	1
- Layout	E-PC137421	13.11.2008	7



**Enclosure 3**

**Sheet 1**

To Certificate No.: EN-ST-000196

Date : 29-05-2019

Instructions for the application of the approval component/system (see enclosure 1):

1. To use the FlexC features, the SPC I-CIE shall be equipped with software V3.6.6 or higher.
2. The device complies with Environmental Class II of EN 50130-5:2011.
3. The device is suitable to provide alarm transmission according to category SP2 in line with EN 50136-1:2012.
4. The device complies with EN 50130-4:2011 + A1:2014.